



Water Truck Inspection Form

Distribution Water Quality & New Service Tel: 913.895.1815
10747 Renner Blvd., Lenexa, Kansas 66219-9624 Fax: 913.895.5607

IF FIRE HYDRANT METER IS NEEDED YOU MUST FILL OUT A FIRE HYDRANT METER APPLICATION

PLEASE FILL OUT ONE FORM PER TANK INSPECTION

Meters are available for pickup between 9am to 3pm M-F with a 24 hour notice.

**Fields Required Requestors Information

**** Requested Inspection Date:** **** # of Tanks:**

**** Company Name:**

**** Billing Address:**

**** Physical Address:**

**** City:** **State:** **Zip Code:**

**** Contact Person:**

**** Phone No.** **Alt. Phone No.:**

Bulk Tank Filling Conditions

1. All tanks must display a current inspection sticker.
2. When filling a top fill tank **with** permanently mounted piping, the outlet pipe must be properly air gapped.
3. When a top fill tank **without** permanently mounted piping is filled through a hose, the hose outlet must be equipped with a permanent air gap fitting.
4. When a tank is filled with a 1-inch or smaller hose, a hose bibb vacuum breaker must be attached to the discharge end of the hose.
5. Bottom fill tanks must be properly equipped with an approved Reduced Pressure Assembly (RPA). The R.P.A. must be tested by a qualified tester each month with the test results sent to the Distribution Water Quality and New Service Department no later than the first working day of each month or the permit will be canceled.

Please direct all questions regarding backflow prevention and air-gaps to the Distribution Water Quality and New Service Department at (913) 895-1815.

Print a copy for your records

To be filled out by WaterOne Personnel Only

Time of Inspection: _____ **TYPE OF BACKFLOW PROTECTION:**

AIR GAP HOSE END AIR GAP RPA

RESULTS:

FAILED Inspected by: _____

APPROVED Inspected by: _____

REMARKS: _____

Accepted by: _____ Date: _____